


| REVISIONS |               |           |          |
|-----------|---------------|-----------|----------|
| REV.      | DESCRIPTION   | DATE      | APPROVED |
| A         | REDRAWN IN SW | 7/10/2009 | BEM      |



| HOUSING MATERIALS |                |
|-------------------|----------------|
| BODY:             | GRAY POLYAMIDE |

| UNLESS OTHERWISE SPECIFIED:          |           | NAME |
|--------------------------------------|-----------|------|
| DIMENSIONS ARE IN INCHES<br>AND [MM] | DRAWN     | DWM  |
|                                      | CHECKED   |      |
|                                      | ENG APPR. |      |
|                                      | MFG APPR. |      |
|                                      | Q.A.      |      |
| MATERIAL                             | COMMENTS: |      |
| FINISH                               |           |      |
| DO NOT SCALE DRAWING                 |           |      |

| MENCOM CORPORATION |          |              |
|--------------------|----------|--------------|
| TITLE:             |          |              |
| SIZE               | DWG. NO. | REV          |
| B                  | CK-03VA  | A            |
| SCALE: 1:1         | WEIGHT:  | SHEET 1 OF 1 |

PROPRIETARY AND CONFIDENTIAL  
THE INFORMATION CONTAINED IN THIS  
DRAWING IS THE SOLE PROPERTY OF  
MENCOM CORPORATION. ANY  
REPRODUCTION IN PART OR AS A WHOLE  
WITHOUT THE WRITTEN PERMISSION OF  
MENCOM CORPORATION IS  
PROHIBITED.

SEAL RATING OF IP 65 ONLY ACHIEVED WHEN FULLY  
LATCHED TO MATING BASE AND WITH AN APPROPRIATE  
SEALING GLAND INSTALLED AND CKR-65 SEALING KIT.  
WITHOUT CKR-65, SEALING RATED AT IP44