



These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.

| HOUSING MATERIALS | |
|-------------------|--------------------------------|
| BODY: | EPOXY COATED DIE CAST ALUMINUM |
| GASKET: | THERMOPLASTIC ELASTOMER |
| HANDLE: | POLYAMIDE |
| LEVERS: | STAINLESS STEEL |

| PIC RATINGS/SPECIFICATIONS | |
|----------------------------|---------------------------------|
| VOLTS: | 250V |
| AMPS: | 3A |
| SCCR: | 0.2kA |
| NEMA/UL EN 60529: | 4, 4X, 12 IP65 |
| MOUNTING SCREW SIZE: | M4 (8-32) (304 or 316SS for 4X) |
| MOUNTING SCREW TORQUE: | 1.2~1.8N-m (0.9~1.3 Lb-Ft) |
| INCOMING POWER WIRE SIZE: | 0.5 ~ 4.0 sq mm / 20-12AWG |
| WIRE STRIP LENGTH: | 10 ~ 11 mm |

MOUNTING KIT ORDERED SEPARATELY CONTAINS M4x0.7 SS SCREW, NYLON WASHER, SPLIT LOCKWASHER AND M4 NUT
P/N: D-PIC-MT

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MENCOM CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MENCOM CORPORATION IS PROHIBITED.

| |
|-----------------------------------|
| UNLESS OTHERWISE SPECIFIED: |
| DIMENSIONS ARE IN INCHES AND [MM] |
| MATERIAL |
| FINISH |
| DO NOT SCALE DRAWING |

| | |
|------------|------------|
| DRAWN BY | DCG |
| DRAWN DATE | 08/23/2018 |
| CHECKED BY | JJH |
| CHECK DATE | 08/23/2018 |

| | | |
|---|-------------------------|-----------------|
| MENCOM CORPORATION | | |
| TITLE: EURO (SCHUKO) RCPT; DB9; 3A; 32 | | |
| SIZE B | DWG. NO. EP-DB9-R-32 | REV D |
| SCALE: 2:3 | WEIGHT: | SHEET 1 OF 1 |

| STANDARD CONFIGURATIONS UNLESS OTHERWISE NOTED | | |
|--|----------|----------|
| CONN. TYPE | EXTERIOR | INTERIOR |
| ALL D-SUBS | FEMALE | MALE |