COMPACT Splicing Connector; for all conductor types; for Ex e applications; max. 4 mm²; 3-conductor; with levers; transparent housing; Operating temperature (max.): 105 °C; 4,00 mm²; transparent



https://www.wago.com/221-483






Color: transparent









Dimensions in mm

https://www.wago.com/221-483

W/AGO

Your benefits:

- Ease of use pull the lever up, insert a conductor and push the lever back down
- Available as 2-, 3- and 5-wire connectors
- Easily terminate conductors from 0.14 to 4 mm²
- · Connect solid, stranded and fine-stranded conductors
- Save time for installers and device manufacturers
- Quickly install devices with higher power consumption
- Safely install long cable runs with larger conductor cross sections
- Mounting carrier for installation conforms to standards
- Working voltages of 275 V or 440 V
- · Custom carriers are possible
- ATEX (Ex 2 II G), IECEx (Ex eb IIC Gb) Zone 1, 2
- IECEX (Ex eb IIC Gb), American Ex (AEx eb IICGb) / Class 1, Zone 1

Notes	
Safety information 1	The permissible operating voltage of the connector with carrier (440 V or 275 V) depends on the mounting type.
Safety information 2	Only approved in conjunction with a mounting carrier (221-501). Other carriers are possible, see certificate/file. The connectors must be installed in an enclosure meeting the requirements of a recognized protection type per EN 60079-0, Section 1 or EN 60079-31. When installing the connectors in an enclosure of protection type "eb" (increased safety) per EN 60079-7, the clearances and creepage distances of Table 2 for this standard must be observed. See point 1 for the use of accessories. The connectors can be used both in Group II and Group I, as the standard requirements are identical in this case. The use of these components requires a new assessment by a notified certification agency.

Electrical data			
Ratings per IEC/EN		Ratings per UL 1059	
Ratings per	IEC/EN 60079-7	Approvals per	UL 60079
		Rated voltage UL (Use Group C)	440 V
		Rated current UL (Use Group C)	20 A

Ex information	
Ratings per	ATEX: PTB 18 ATEX 1019 U / IECEx: PTB 18.0045U (Ex eb IIC Gb)
Rated voltage EN (Ex e II)	440 V
Rated current (Ex e II)	32 A

Connection data		
Connection points 3	Connection 1	
Total number of potentials 1	Connection technology	CAGE CLAMP®
	Actuation type	Lever
	Connectable conductor materials	Copper
	Fine-stranded conductor	0.14 4 mm² / 24 12 AWG
	Wiring direction	Side-entry wiring

https://www.wago.com/221-483



Material Data	
Note (material data)	
	Information on material specifications can be found here
Color	transparent
Flammability class per UL94	V2
Fire load	0.064 MJ
Actuator color	light gray
Weight	2.7 g

Commercial data	
eCl@ss 10.0	27-14-11-04
eCl@ss 9.0	27-14-11-04
ETIM 8.0	EC000446
ETIM 7.0	EC000446
PU (SPU)	500 (50) pcs
Packaging type	Вох
Country of origin	DE
GTIN	4055143837347
Customs tariff number	85369010000

Approvals / Certificates

General approvals





UL 486C

Approval Standard Certificate Name

CCA EN 60998 NTR NL-7827

DEKRA Certification B.V.

ENEC 05 EN 60998 71-113253 REV.1

DEKRA Certification B.V.

E69654

Underwriters Laboratories

Inc.

Approvals for marine applications



Approval Standard Certificate Name

LR EN 60998 LR22207029TA

Lloyds Register


Approvals for hazardous areas




Approval	Standard	Certificate Name
AEx Underwriters Laboratories Inc.	UL 60079	E185892 (AEx eb IIC resp. Ex eb IIC)
CCC CNEX	GB/T 3836.3	2020312313000184 (Ex eb IIC Gb, Ex eb I Mb)
EAC Brjansker Zertifizierungs- stelle	TP TC 012/2011	RU C-DE.AM02. B.00127/19 (Ex e IIC Gb U)
IECEx Physikalisch Technische Bundesanstalt	IEC 60079-0	IECEx PTB 18.0045U (Ex eb IIC Gb, Ex eb I Mb)



Downloads Environmental Product Compliance Compliance Search Environmental Product Compliance 221-483







Item No.: 221-500/000-006

Mounting carrier; 221 Series - 4 mm²; for DIN-35 rail mounting/screw mounting; blue

Item No.: 221-501

Mounting carrier; for Ex applications; 221 Series - 4 mm²; for DIN-35 rail mounting/ screw mounting; light gray

https://www.wago.com/221-483



Installation Notes

Conductor termination



Strip conductor to 11 mm (0.43 inch).



Then, lower the lever to close the clamp.



Termination: Lift the lever to open the clamping unit and insert a stripped conductor.

Installation



Inserting a connector into the mounting carrier



Removing a connector from the mounting carrier.



Removing a conductor.



Mounting type (440 V)
Using spacers between the connectors.



Mounting type (440 V) Vertical mounting on DIN-35 rail



Mounting type (440 V) Horizontal screw mounting on a flat surface



Mounting type (440 V)
Mounting the carrier via non-conductive



Mounting type (275 V) No spacers are used between the connectors.



Mounting type (275 V) Mounting the carrier using conductive screws.

Testing



Easily test inserted connectors in the carrier – however they are mounted.

Subject to changes. Please also observe the further product documentation!

Current addresses can be found at:: $\underline{www.wago.com}$

Page 5/5 Version 12.01.2023