



GALLONS PER MINUTE (GPM) = FLOOR AREA / 13

-50% FURTHER FLOW REDUCTION FOR FIRE SPRINKLERS SHOWN IN GRAPH ABOVE

-MINIMUM REQUIRED FLOW OF 500 GPM @ 20 PSI RESIDUAL

FIGURE: 4a-1

WATER SUPPLY REQUIREMENTS

**MONTECITO FIRE
DEPARTMENT**