

**200 FT. MAXIMUM DISTANCE FROM  
ACCESS POINT TO THE MOST REMOTE  
PART OF A RESIDENTIAL STRUCTURE  
(150 FT. NON-RESIDENTIAL)**

**PROPOSED STRUCTURE**

**FIRE APPARATUS  
AT ACCESS POINT**

**TRAVEL DISTANCE FROM ACCESS POINT  
TO FIRE HYDRANT:**

**300 FT. - NON RESIDENTIAL  
500 FT. - RESIDENTIAL  
700 FT. - RESIDENTIAL WITH FIRE  
SPRINKLERS**

**ACCESS DRIVE**

**FIRE HYDRANT**

**FIGURE: 4a-2**

**FIRE APPARATUS ACCESS  
TRAVEL DISTANCE FROM HYDRANT**

**MONTECITO FIRE  
DEPARTMENT**