

AUTOMATIC FIRE SPRINKLER SYSTEM STANDARDS

Development Standard #4

- I. Fire sprinkler plans are required to be checked and approved by this department prior to installation. Any system must be in compliance with current NFPA Standard #13 or #13D or #13R as, applicable.
 - A. Any work being undertaken by the applicant (including applicant's agents or contractors) shall be in accordance with the following:
 1. The fire department shall determine the location of any fire department connection (FDC) that may be required.
 2. The fire department shall have on file a set of approved plans prior to any work being done.
 3. A set of approved plans, stamped and dated by the fire department shall be kept at the work site and available upon request.
 4. Water systems shall be installed exactly as the approved plans dictate. No changes or modifications to these plans shall take place without prior fire department approval.
 5. No work shall be covered or otherwise rendered inaccessible or unviewable prior to inspection by a fire department representative.
 6. A minimum of 48 hours notice shall be given to the fire department by the applicant prior to scheduling an inspection.