

Addendum No. 3 to Quote #2023-22



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Procurement and Contracting Services
KATJANA BALLANTYNE
MAYOR

To: All Parties on Record with the City of Somerville as Holding Quote #2023-22
Winter Hill School Air Separator Tank Replacement

From: Jordan T. Remy

Date: 3/15/2023

Re: Questions and Answers

Addendum No. 3 to Quote #2023-22

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 3 to Quote #2023-22

Extension of Deadlines

The deadline to submit a quote has been extended to 3/31/2023 at 11:00am.

Anyone who has submitted a quote already may amend their submission. Please acknowledge all addenda and use the updated quote form.

Questions and Answers

- 1. Question: Is the awarded vendor responsible for draining the lines before conducting repair or replacements, and upon completion is the awarded vendor responsible for refilling the lines/system to proper capacity?**

Answer: Yes, the awarded vendor will be responsible for draining and refilling the lines/system.

- 2. Question: What if the isolation valves don't hold pressure?**

Answer: The awarded vendor would need to drain the system below the tank and complete work as scheduled.

The awarded vendor will make the owner or City designee aware and issue a quote to replace the failed valve.

- 3. Question: What if the flanges don't line up or are deteriorated to the point of no longer being useful.**

Answer: It is anticipated that one of the existing flanges will not line up with the new tank. Vendor should include a new flange and pipe modification to align with the new tank.

If condition of remaining flange is such that it is not reusable, the awarded vendor will make the owner or City designee aware and issue a quote to replace the bad flange.