

Addendum No. 2 to IFB 25-14



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Procurement and Contracting Services
KATJANA BALLANTYNE
MAYOR

To: Bidders of IFB 25-14 Pre-Cast Concrete Curb Procurement and Installation

From: Andrea Caruth, Deputy Chief Procurement Officer

Date: October 17, 2024

Re: Response to Bidder Questions and Bid Opening Extension

Addendum No. 2 to IFB 25-14

****Please note: the Bid Opening Date is extended to Thursday, October 24th, 2:00PM.****

This addendum responds to bidder questions.

**** Failure to acknowledge this addendum may result in bid disqualification.****

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ #2 _____ #3 _____ #4 _____

Addendum No. 2 to IFB 25-14

#	Questions	Response
1	No specifications or details provided for the proposed flex posts to be mounted on the precast bike lane separators. Please advise on installation of flex post (ex: mounted with base plate and anchors, cored and grouted, etc.)	Flex posts shall be white, 36" in height with a 3" diameter and two retroreflective bands. Coring and grouting or embedding an anchor cup are both acceptable methods of adhering the post to the concrete curb.
2	Will existing flexible delineator posts be removed by others?	Yes, any existing flexible delineator posts will be removed by others.
3	We assume that roadway markings, high friction surface coloring, and route/regulatory signs as shown on pages 121-125 are to be installed by others. Please confirm that these items are excluded from the scope of work under this project.	Correct. Roadway markings, high friction surface coating, and route/regulatory signs are all excluded from the scope of work.