

Addendum No. 2 to IFB 25-22



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Procurement and Contracting Services
KATJANA BALLANTYNE
MAYOR

To: Bidders of IFB 25-22 Community Path Extension – Additional Lighting

From: Andrea Caruth, Deputy Chief Procurement Officer

Date: January 21, 2025

Re: Responses to Bidder Questions

Addendum No. 2 to IFB 25-22

This addendum shares responses to bidder questions.

**** Failure to acknowledge this addendum may result in bid disqualification.****

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ #2 _____ #3 _____ #4 _____

Addendum No. 2 to IFB 25-22

#	Questions	Response
1	Is there a model of luminaires that are the basis of design?	Luminaire basis of design manufacturer and model number included on sheet CMP-E-0001 in the Luminaire Schedule.
2	What's the finish of the conduit?	Refer to specification section 260533 for all conduit type requirements. Exposed conduit: GRC
3	Is there vehicle access on the path?	There is vehicle access on the path. Access should be minimized and will not include parking along the park. Access will also need to be coordinated with the City.
4	Drawing CMP-E-8001; details a typical rub rail elevation; please confirm we are correct in our understanding, that rub rail splice plates occur @ 12'ft lengths. As detailed an expansion fitting is required for both line and low voltage raceways.	Correct, the rub rail expansion joints occur nominally every 12ft along the length of the rail.
5	Please confirm / clarify if ½ "conduit can be used for the low voltage lighting raceways (driver to luminaires)	No exception taken to the use of 1/2 "conduit for the low voltage lighting raceways (driver to luminaires)
6	Please confirm if the electrical permit fees are waived	Yes, all City permit fees are waived