

Addendum No. 1 to IFB #25-41



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Procurement and Contracting Services
KATJANA BALLANTYNE
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB #25-41 Central Hill
Campus Korean and Vietnam Memorial Installation

From: Felisa Gárate

Date: 3/7/2025

Re: Questions and Answers
Additional Photos of the Korean and Vietnam Memorials

Addendum No. 1 to IFB #25-41

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 1 to IFB #25-41

#	Question	Answer
1.	Who owns the property where the memorials are located at 133-134 Inner Belt Road?	It is private property, owned by the business(es) located at 200 Inner Belt Road.
2.	How long have the monuments been at the 133-134 Inner Belt Road location?	Approximately 6 years.
3.	What is the weight of the Vietnam War Memorial?	The weight of the Vietnam Memorial is estimated at 10.25 tons.
4.	Does the City have pictures of what the memorials previously looked like?	Images can be found on the first page of the drawings. Additional photos are also provided with this addendum by following the link below.
5.	There are multiple memorials at the 133-134 Inner Belt Road site, besides the Korean and Vietnam memorials. Will someone from the City of Somerville be on site to point out the correct memorials for this project?	The design team (SMMA and BCA) will be.
6.	Is there just one leg missing from the Vietnam War Memorial benches?	Yes, specifically from the U.S. Navy bench.
7.	Do you have manufacture details for the Vietnam War Memorial benches?	No, the City does not have this information. The benches are over 20 years old.
8.	Is there any consideration for the contractor to work off-hours at the construction site?	This is possible, and could be arranged with the awarded vendor. Sundays are not possible.
9.	Would the construction site be busy on a Saturday?	Yes, the site is always busy.
10.	<p>I wanted to confirm with you that we are solely bidding on the installation of the memorials and the drainage associated with them and that the irrigation plans found on page 11 and 12 of the spec binder doc are simply for reference.</p> <p>In other words, the irrigation documents are not part of this bid involving the installation of the memorial, correct?</p>	<p>Bidding on the modification of the existing irrigation system <u>IS</u> part of the scope of work for this project. A Planting Irrigation specification is included in the binder for performance requirements. The attached documents of the existing system are <u>For Reference Only</u>, and should be verified in field by the Contractor.</p>

Addendum No. 1 to IFB #25-41

Attachment 1

Additional Photos of the Korean and Vietnam Memorials

Please access via Google Drive here:

<https://drive.google.com/drive/folders/1vRNsWVWfD4WxcL3Unn4l7HU69WPEKuPd?usp=sharing>