

Addendum No. 1 to IFB #25-57



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Procurement and Contracting Services
KATJANA BALLANTYNE
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB #25-57 Irrigation System Maintenance at Lincoln Park

From: Felisa Gárate, Procurement Analyst

Date: 4/10/2025

Re: Questions and Answers from Site Visit

Addendum No. 1 to IFB #25-57

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 1 to IFB #25-57

#	Question	Answer
1.	Is the tank under the basketball court filled by a well or by City water?	The tank is filled either by recycled rainwater through the UV filtration system or by well water. No domestic water.
2.	Is there a functioning flow sensor connected to the system?	Yes. The hydrometer was installed by Winterberry in July 2020.
3.	Are the drinking fountains, splash pad and community garden spigot at Lincoln Park included in this bid?	The drinking fountains, splash pad and community garden spigot are on City water and should be included under the On-Call Repairs contract (IFB 25-58), and <u>not</u> this bid.