

**Addendum No. 1 to Request for Quotes 2025-23**



**CITY OF SOMERVILLE, MASSACHUSETTS**  
**Department of Procurement and Contracting Services**  
**KATJANA BALLANTYNE**  
**MAYOR**

To: All Parties on Record with the City of Somerville as Holding Request for Quotes 2025-23  
Conway Park Basketball Court Repainting

From: Felisa Gárate, Procurement Analyst

Date: 6/23/2025

Re: Questions and Answers  
Sign-In Sheet From Mandatory Site Visit on 6/18/2025  
Extension of Quote Submission Deadline

**Addendum No. 1 to Request for Quotes 2025-23**

---

**Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.**

**NAME OF COMPANY / INDIVIDUAL:** \_\_\_\_\_

**ADDRESS:** \_\_\_\_\_

**CITY/STATE/ZIP:** \_\_\_\_\_

**TELEPHONE/FAX/EMAIL:** \_\_\_\_\_

**SIGNATURE OF AUTHORIZED INDIVIDUAL:** \_\_\_\_\_

**ACKNOWLEDGEMENT OF ADDENDA:**

**Addendum #1** \_\_\_\_\_ **#2** \_\_\_\_\_ **#3** \_\_\_\_\_ **#4** \_\_\_\_\_

**Addendum No. 1 to Request for Quotes 2025-23**

The City of Somerville is extending the quote submission deadline to: **Thursday, June 26<sup>th</sup>, 2025 at 2PM EST.**

#	Question	Answer
1.	What is the estimated project cost?	\$22,000.00
2.	When were the courts last resurfaced?	3-4 years ago, when the athletic field at Conway Park was built.
3.	Will the pickleball courts be centered on the halves of the basketball court?	Yes, with not shared lines between the basketball and pickleball court lines.
4.	Is the basketball court key to remain gray?	Yes. The colors will be kept the same as the existing paint job.
5.	What size will the pickleball courts be? The existing pickleball courts are not regulation size.	The new pickleball courts will be regulation size, 20 ft. × 44 ft. The 20 ft. length will be centered between the half court line and foul line of the basketball court. The 44 ft. length will be centered on the short dimension of the basketball court.
6.	Does the scope of work include power washing?	Yes. The scope of work includes all proper prep work, repainting and relining.
7.	Where can we park our trailers/equipment?	DPW will arrange for sufficient parking in the lot next to the basketball courts.
8.	Who will be responsible for keeping the courts clear and blocked off during the curing process?	The Contractor will be responsible for all fencing or other materials required to prevent public access to the court while the new paint cures. DPW will lock the two gates from the skating rinks.
9.	Will one court be painted at a time to keep the other usable?	No. Both courts will be repainted at one time. The entire fenced-in area around the courts will be closed to the public while the courts are being repainted.
10.	What is the total linear footage of all lines to be painted?	Basketball courts (white textured line paint): Approx. 1,700 linear feet  Pickleball courts (yellow textured line paint): Approx. 792 linear feet
11.	Is there a warranty included?	All finished work shall be covered by a three-year warranty from any defects in quality. If, at any time within three years after the

**Addendum No. 1 to Request for Quotes 2025-23**

		completion of the contract, any defective work should appear, which in the opinion of the City is due to inferior materials or workmanship, the City will notify the Contractor in writing of the defects and repairs to be made. The Contractor shall begin the repairs within a mutually agreed time frame and shall do whatever is necessary to remedy the defects without cost to the City.
12.	Can you provide the sign-in sheet from the mandatory site visit?	Please see the attached.

**Request for Quotes 2025-23 Conway Park Basketball Court Repainting: Mandatory Site Visit 1:00PM June 18, 2025**

[illegible]