
GF SPRAGUE EXTERIORS

JUN 16, 2025






FERNANDO LEON

73 COLUMBUS AVE, #2 Somerville, MA 02143



INSPECTION



All gutters to be 5k white aluminum. 3x4 downspouts.



ALL DOWNSPOUTS 3X4 ALUMINUM.



SHINGLE ROOF.



EPDM ON BAY ROOF.



REMOVE DECKING AND RAILINGS AND STORE.



REPLACE COPPER VALLEY.
HIGH TEMP ICE AND WATER SHIELD UNDER ALL COPPER.



EPDM ROOFING MATERIAL. FLASH WALL TO ROOF JUNCTURE. FLASH EPDM TO SLATE TRANSITION.