

**Addendum No. 1 to Request for Quotes#2026-11**



**CITY OF SOMERVILLE, MASSACHUSETTS**  
**Department of Procurement and Contracting Services**  
**KATJANA BALLANTYNE**  
**MAYOR**

To: All Parties on Record with the City of Somerville as Holding Request for Quotes#2026-11  
**Crack Sealing at DPW Yard**

From: Logan J. Carroll

Date: 10/28/2025

Re: Deadline Extension and Questions & Answers

**Addendum No. 1 to Request for Quotes # 2026-11**

---

**Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.**

**NAME OF COMPANY / INDIVIDUAL:** \_\_\_\_\_

**ADDRESS:** \_\_\_\_\_

**CITY/STATE/ZIP:** \_\_\_\_\_

**TELEPHONE/FAX/EMAIL:** \_\_\_\_\_

**SIGNATURE OF AUTHORIZED INDIVIDUAL:** \_\_\_\_\_

**ACKNOWLEDGEMENT OF ADDENDA:**

**Addendum #1** \_\_\_\_\_ **#2** \_\_\_\_\_ **#3** \_\_\_\_\_ **#4** \_\_\_\_\_

## **Addendum No. 1 to Request for Quotes#2026-11**

### **Deadline Extension**

**This addendum extends the deadline for bid submissions until 10/31/2025 at 11:00 AM**

### **Questions & Answers**

1. What is the plan for moving vehicles, dumpsters, etc. to open up the work area? Will the entire Yard be cleared so it can be sealed in one mobilization, or will the work be done in phases?
  - a. DPW will clear one half of the Yard at a time. The work will be done in two (2) mobilizations.
2. The asphalt is in poor condition in some areas. Does the scope of work cover only crack sealing, or is the contractor responsible for hot top patches too?
  - a. The scope of work includes crack sealing only. DPW will patch damaged areas with hot top before work begins.
3. Will the dumpsters and storage bays be moved/cleared out so cracks can be sealed there? The roll-off containers by the salt shed have sediment under/around them that may be hard to clean thoroughly enough for the sealant to adhere properly.
  - a. DPW will expose all asphalt and sweep before work begins. We will move the roll offs and sweep under them.
4. Should the contractor submit a report of additional work needed for best outcome of crack sealing work?
  - a. DPW will take recommendations, but it is not a required component of the project.
5. When will the work be scheduled? Weekdays during regular hours, overnight, weekend?
  - a. Weekday evenings. Work can begin no earlier than 4:00 PM so that crack sealing isn't taking place during normal DPW operations.
6. The specifications call for a roadway filler product. There is a parking lot product available that's less sticky for vehicles parked on top for long periods. Should the contractor use the product identified in the specifications, or a parking lot product?
  - a. Parking lot product such as SealMaster Crackmaster Parking Lot Grade sealant or equivalent
7. Do you want the work completed before the end of the year? What's the timeline for the project?
  - a. Weather permitting, DPW would like to complete the work as soon as possible. Work may be scheduled during the winter if weather permits, or in early spring. The project schedule will be coordinated by the Contractor and the DPW Commissioner or Designee.