

Addendum No. 1 to IFB #26-70



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Procurement and Contracting Services

JAKE WILSON
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB #26-70 Kennedy School Parking & Playground Construction Phase I

From: Felisa Gárate, Senior Procurement Manager

Date: 5/11/2026

Re: Revisions to Specification Section 26 56 00

Addendum No. 1 to IFB #26-70

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 1 to IFB #26-70

Specification Section 26 56 00, Site Lighting, inadvertently included language related to options in the Basis-of-Design product which are not in use on the project (the Drawings are correct as written). For clarity, the following changes are being made to Specification Section 26 56 00, Site Lighting, to bring the Specifications into conformance with the Drawings:

- In 1.1.B.1, delete the reference to Items 2.4 and 2.5 from the list of Basis-of-Design specifications used; this paragraph only applies to 2.2 and 2.3.
- In 2.2.A.2.a, Anchor Base, delete the sentence "A cast aluminum hinged base (HB) secured with bolts and shims in which aluminum shaft is slipped over." The project does not require a hinged base.
- Delete paragraphs 2.2.A.6.a and 2.2.A.6.b (Duplex Receptacle, DR and GF). The project does not require DR or GFI options.