

160 Sylvan Street Danvers, MA 01923

Structural Design & Sales www.mcbrie.com

Telephone: 978-646-0097

Fax: 978-646-0087

July 26, 2017

Mr. George Proakis Director of Planning City of Somerville, City Hall 93 Highland Avenue Somerville, MA 02143

RE: EXISTING BRICK CHIMNEY CONDITION

at the Redevelopment of 21 Murdock Street 21 Murdock Street, Somerville, MA 02145

McBrie, LLC Project #17-190

Dear Mr. Proakis:

McBrie, LLC has been asked to evaluate the existing unreinforced brick chimney at the above referenced project to determine if it is safe for the proposed redevelopment at the site.

It is McBrie, LLC's opinion that maintaining a chimney of this aspect ratio (height to width) is a seismic hazard to proposed surrounding structures. This is due to its construction method which only provides very minimal lateral and uplift load resistance and is very susceptible to failure during a seismic event.

Therefore if the chimney is not active, McBrie, LLC recommends that it be removed as part of the development of this project.

Please do not hesitate to contact our office if you require additional information.

Sincerely,

Michael Perham, PE

Structural Engineer / Managing Member

cc: Peter Quinn, Joseph Flaherty