

NOTIFICATION OF CONSTITUENTS IN GROUNDWATER ABOVE GWPS – ASH BASIN 6

**Brunner Island Steam Electric Station (Brunner Island, LLC)
East Manchester Township, York County, Pennsylvania
U.S. EPA Coal Combustion Residuals Rule**

February 13, 2019

NOTICE

Pursuant to 40 CFR §257.95(g) and 40 CFR §257.107(h)(6), constituents have been detected at statistically significant levels (SSL) above the groundwater protection standards (GPWS) in the groundwater monitoring network for Ash Basin 6, an ash impoundment, located at the Brunner Island Steam Electric Station, in East Manchester Township, York County, Pennsylvania. During the November 2018, the following constituents were detected in the indicated groundwater monitoring wells:

- Arsenic in MW-6-3N and MW-6-7
- Lithium in MW-6-3N and MW-6-7
- Molybdenum in MW-6-3N, MW-6-4, MW-6-7, and MW-8-2.



Prepared by:



a Montrose Environmental Group company

West Chester, PA