

PERFORMANCE EVOLUTION: #E-1

1 3/4" Quick Attack - Tank Water



- Tactical Objective:** Rapidly deploy a 1 3/4" pre-connect attack line utilizing tank water
- Given:** 3-person crew, full PPE, engine company with a 1 3/4" attack line 200' long, 2 SCBAs, set of irons and three portable radios
- Performance:** The engine company will rapidly deploy a 200' 1 3/4" pre connected attack line within 150' of apparatus
- Standard:** Within 1 minute and 30 seconds, in a safe and efficient manner. Time starts when engine stops at simulated fire scene, and time stops when an effective fire stream is developed, relief valve set, nozzle team is in full PPE with mask on, and all personnel are with portable radio.

Reference: SOG #'s 53.101, 53.106

Critical Assessment (30 second penalty for each item missing)

Tires chocked	Relief valve set	Officer w/irons
Line w/no kinks	Personnel w/radios	Correctly pulled
Correct EP	SCBA mask on	

Eng. #:	Shift:	Date:	BC Sign-off:
Captain:	Engineer:	Firefighter:	
Rater:	Pass / Fail:	Time:	# Attempts:

PE - #E-01 Attack Without Supply - 7/6/05 jtw	RETURN COMPLETED FORM TO TRAINING DIVISION	Date Received:
---	--	----------------