

## PERFORMANCE EVOLUTION: #E-2

### 5" Dry Forward Lay with Quick Attack



**Tactical Objective:** Rapidly initiate a quick attack operation using a 1 3/4" cross-lay with an uncharged supply line laid into the scene.

**Given:** 3-person crew, full PPE, SCBA, Type I Engine, fire hydrant and area large enough to lay 150' of supply line and pull 200' of attack line.

**Performance:** Crew will perform a dry 5" forward hose lay and then quickly deploy a 1 3/4" attack line. Supply line in this evolution will be between 150' and 200' long.

**Standard:** Within 2 minutes, in a safe and efficient manner, personnel will lay a dry 5" supply line from a hydrant to the fire area and then deploy a 1 3/4" attack line. Time starts when engine stops at hydrant, time stops when a proper fire stream is achieved and attack line personnel are with SCBA, portable radio and set of irons.

#### Critical Assessment (30 second penalty for each item missing)

Engine within 8' – 10' past hydrant	Line wrapped 360 degrees around hydrant base	Wheels chocked
Engineer immediately connecting supply into pump inlet	All personnel with proper PPE and radio	Engine at appropriate engine pressure with relief valve set

Eng. #:	Shift:	Date:	BC Sign-off:
Captain:	Engineer:		Firefighter:
Rater:	Pass / Fail:		Time: # Attempts:

PE - #E-02 Attack With Dry Supply - 7/6/05 jtw	RETURN COMPLETED FORM TO TRAINING DIVISION	Date Received:
--	--	----------------