



Certificate of Compliance

Certificate: 80271578

Master Contract: 607184

Project: 80271578

Date Issued: October 10th, 2025

Issued to: EdisonFlex Wire & Cable and Edison Elm Inc.
4030 8 Street SE
Calgary , Alberta T2G 3A7
CANADA
Attention: Jonathan Regidor

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Amos Zheng*
Amos Zheng

PRODUCTS

CLASS C5832-02 WIRES Thermoplastic

Types TW and TWU 60C dry/wet, TW75 and TWU75 75C dry/wet, single conductor constructions with PVC insulation, rated 600V, FT1, optional FT2, VW-1, SR, PR I, PR II, GR I and GR II, copper conductor sizes 14 AWG to 2000 kcmil, aluminum conductor sizes 12AWG to 2000 kcmil.

Types T90 Nylon 90C dry, TWN75 75C dry/wet, single conductor constructions with PVC insulation and Nylon jacket, rated 600V, FT1, optional FT2, VW-1, SR, PR I, PR II, GR I and GR II, copper conductor sizes 14 AWG to 1000 kcmil, aluminum conductor sizes 12AWG to 1000 kcmil.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 75 (update no.1) - Thermoplastic-Insulated Wires and Cables



Certificate: 80271578


Master Contract: 607184

Project: 80271578

Date Issued: October 10th, 2025

Notes:

Products certified under Class C5832-02 has been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Certificate: 80271578

Master Contract: 607184

Project: 80271578

Date Issued: October 10th, 2025

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark, without any adjacent indicators, indicating that products have been manufactured to the requirements of Canadian Standards.

Label Service

This product requires participation in the Label Service Program.

CSA Labels are only available from CSA Group but are applied at the factory.

On the Product:

Finished products shall be marked durably and legibly with the following information, at intervals not exceeding 1.0m, except for conductor size, which shall be repeated at intervals not exceeding 610 mm:

- Submitter's identification (submitter's name, or the Master Contract "607184");
- Type designation;
- Optionally, maximum operating dry and wet temperature rating of insulation;
- Conductor size expressed as "mm² (AWG)", "AWG (mm²)", "mm² (kcmil) or "kcmil (mm²)" as applicable;
- Conductor class, if more finely stranded than Class B or C stranding. Optional for SIW or combination unilay stranding;
- For types with aluminum conductors shall be marked "AL", and additional marking "ACM" shall be optional;
- Voltage rating: "V", "volts", or "VOLTS";
- Optional Flame marking "FT2", "FT1" or "VW-1", if applicable;
- Optional Weather Resistance marking "SR", "Sunlight Resistant" or "Sun Res";
- Optional Oil resistance marking "PRI" or "PRII", if applicable;
- Optional Gasoline and oil resistance marking "GR I" or "GR II", if applicable; and,
- The CSA monogram  or the word mark "CSA".

Note: The above marking shall be surface printing.

On the Packaging:

Each coil or reel of cable is clearly tagged or marked to show the following:

- Submitter's identification (as above);
- Type designation;
- Conductor size (as above);
- "AL" after the conductor size, when aluminum conductor is used. Additional marking "ACM" shall be optional;



Certificate: 80271578

Master Contract: 607184

Project: 80271578

Date Issued: October 10th, 2025

- If compact stranding is used, the word “COMPACT” or “CMPCT”;
- Voltage rating (s);
- Optionally, the maximum operating dry and wet temperature rating of the insulation;
- Date of manufacturing by month and year (a code is acceptable);
- CSA Building Wire and Cable label or authorized use of the CSA Label Licensing Service.



Supplement to Certificate of Compliance

Certificate: 80271578

Master Contract: 607184

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80271578	October 10 th , 2025	MULTIPLE LISTING for “EdisonFlex Wire & Cable and Edison Elm Inc.”, C5832-02, Listee Contract: 607184.

Multiple Listing			
<u>Application/Project No.</u>	<u>Listee Models</u>	<u>Submittor Models</u>	<u>Certification Report No.</u>
80271578	TW	TW	80169086
	TWU	TWU	
	TW75	TW75	
	TWU75	TWU75	
	T90	T90	
	TWN75	TWN75	