



Certificate of Compliance

Certificate: 80271579

Master Contract: 607184

Project: 80271579

Date Issued: October 10th, 2025

Issued to: EdisonFlex Wire & Cable and Edison Elm Inc.
4030 8 Street SE
Calgary , Alberta T2G 3A7
CANADA
Attention: Jonathan Regidor

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Amos Zheng*
Amos Zheng

PRODUCTS

CLASS C5821-02 CABLE Nonmetallic Sheathed

Part A: Type NMD90, rated 90°C, -25°C, 300V, FT1, optional -40°C, two to four conductors, round construction, with PVC insulation and nylon covering, with PVC jacket.

Part B: Type NMD90, rated 90°C, -25°C, 300V, FT1, optional -40°C, two conductors, parallel construction, with PVC insulation and nylon covering, with PVC jacket.

Part C: Type NMD90, rated 90°C, -25°C, 300V, FT1, optional -40°C, two to four conductors, round construction, with XLPE insulation and PVC jacket.

Part D: Type NMD90, rated 90°C, -25°C, 300V, FT1, optional -40°C, two conductors, parallel construction, with XLPE insulation and PVC jacket.

Part E: Type NMWU, rated 60°C, -25°C, 300V, FT1, optional -40°C, two to four conductors, round construction, with XLPE insulation, with PVC jacket.



Certificate: 80271579

Master Contract: 607184

Project: 80271579

Date Issued: October 10th, 2025

Part F: Type NMWU, rated 60°C, -25°C, 300V, FT1, optional -40°C, two conductors, parallel construction, with XLPE insulation, with PVC jacket.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 48-15 (Update No.1) - Nonmetallic Sheathed Cable



Certificate: 80271579


Master Contract: 607184

Project: 80271579

Date Issued: October 10th, 2025

Notes:

Products certified under Class C5821-02 has been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Certificate: 80271579

Master Contract: 607184

Project: 80271579

Date Issued: October 10th, 2025

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark, without any adjacent indicators, indicating that products have been manufactured to the requirements of Canadian Standards.

On the Product

The marking shall be durably and legibly surface ink-printed or embossed on the jacket at intervals of not more than 1m. The marking shall include:

- Submitter's identification (Submitter's name, or Master Contract number "607184");
- Type designation "NMWU" or "NMD90";
- Maximum voltage rating "300V";
- Flame rating "FT1";
- The words "ALUM" or "AL", where aluminium conductors are used, and the additional marking "ACM" may be used;
- Size and number of circuit conductors;
- On two-conductor parallel construction, the low temperature rating "-25°C" or "-40°C" as applicable;
- The words "RED-BLACK" or "ROUGE-NOIR" or both where red and black conductors are used in two - conductor cable; and,
- The CSA monogram  or the word mark "CSA".

On Tags, Reels and Packages

Each coil or reel of cable shall be plainly tagged, and each carton marked on the outside, to show the following:

- Submitter's identification (as above);
- Type designation;
- Date of manufacture by month and year;
- Maximum voltage "300V";
- AWG size and the number of conductors;
- The words "ALUMINUM", "ALUM" or "AL", where aluminium conductors are used, and the additional marking "ACM" may be used;
- The words "RED-BLACK" or "ROUGE-NOIR" or both where red and black conductors are used in two - conductor cable; and,
- The CSA Building Wire/Cable Label.



Certificate: 80271579

Master Contract: 607184

Project: 80271579

Date Issued: October 10th, 2025

Label Service

This product requires participation in the Label Service Program.
CSA Labels are only available from CSA Group but are applied at the factory.



Supplement to Certificate of Compliance

Certificate: 80271579

Master Contract: 607184

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80271579	October 10 th , 2025	MULTIPLE LISTING for “EdisonFlex Wire & Cable and Edison Elm Inc.”, C5821-02, Listee Contract: 607184.
Multiple Listing <u>Application/Project No</u> 80271579	<u>Listee Models</u> NMD90 NMWU	<u>Submittor Models</u> NMD90 NMWU
		<u>Certification Report No.</u> 80169079