

SAFETY MEETING QUIZ

Name:

Date:

Safety Topic: *V1-10 Electrical Safety – Extension Cords and GFCIs*

1. Electrical hazards cause a large number of injuries and fatalities in construction every year.
 - a. True
 - b. False

2. Always _____ your electrical tools and extension cords before use.
 - a. dust off
 - b. have a conversation with
 - c. inspect
 - d. yank around

3. GFCI is short for
 - a. Green Familiar Cord Inside.
 - b. Giant Factory Corporation Incorporated.
 - c. Good Food Causes Indigestion.
 - d. Ground Fault Circuit Interrupter.

4. OSHA Standard 1926.405(a)(2)(ii)(J) states Extension cord sets used with portable electric tools and appliances shall be of _____ and shall be designed for hard or extra-hard usage.
 - a. one-wire type
 - b. two-wire type
 - c. three-wire type
 - d. four-wire type

5. A safety tip that can help prevent serious injuries from happening is
 - a. never use extension cords that have broken or missing ground pins.
 - b. remove frayed, damaged, or severely kinked extension cords from use.
 - c. use GFCIs on construction sites to reduce potential of electrical shocks.
 - d. all of the above.



SAFETY MEETING QUIZ

ANSWER KEY

Safety Topic: V1-10 Electrical Safety – Extension Cords and GFCIs

- Electrical hazards cause a large number of injuries and fatalities in construction every year.
 - True
 - False
- Always _____ your electrical tools and extension cords before use.
 - dust off
 - have a conversation with
 - inspect
 - yank around
- GFCI is short for
 - Green Familiar Cord Inside.
 - Giant Factory Corporation Incorporated.
 - Good Food Causes Indigestion.
 - Ground Fault Circuit Interrupter.
- OSHA Standard 1926.405(a)(2)(ii)(J) states Extension cord sets used with portable electric tools and appliances shall be of _____ and shall be designed for hard or extra-hard usage.
 - one-wire type
 - two-wire type
 - three-wire type
 - four-wire type
- A safety tip that can help prevent serious injuries from happening is
 - never use extension cords that have broken or missing ground pins.
 - remove frayed, damaged, or severely kinked extension cords from use.
 - use GFCIs on construction sites to reduce potential of electrical shocks.
 - all of the above.

