

SAFETY MEETING QUIZ

Name:

Date:

Safety Topic: V2-79 Fire Protection – Fire Watch

1. A fire watch is especially important and useful in areas where there are combustible materials that could be ignited within a 35-foot radius of hot work.
 - a. True
 - b. False

2. The key responsibilities of a fire watch include
 - a. watch for sparks or heat sources that could lead to fires.
 - b. warn workers if tasks are causing an excessive risk of fire.
 - c. extinguish any small or incipient-stage fires immediately.
 - d. all of the above.

3. A fire watch should stay in the area during the work and for at least _____ after the work tasks are finished to monitor all areas where hot work was performed to make sure that there are no smoldering materials.
 - a. 5 minutes
 - b. 30 minutes
 - c. 2 hours
 - d. 12 hours

4. Workers designated to fire watch duty must be equipped with fire-extinguishing equipment readily available for
 - a. Class A and Class B fires.
 - b. energized electrical fires.
 - c. the specific types of fires they may encounter.
 - d. grease fires.

5. The fire watch should only attempt to extinguish a fire if
 - a. they are not sufficiently trained.
 - b. fire trucks are already on the way.
 - c. there are at least two fire extinguishers.
 - d. it is within the capacity of their training and the fire-fighting equipment available.



SAFETY MEETING QUIZ

ANSWER KEY

Safety Topic: V2-79 Fire Protection – Fire Watch

1. A fire watch is especially important and useful in areas where there are combustible materials that could be ignited within a 35-foot radius of hot work.
 - a. True
 - b. False

2. The key responsibilities of a fire watch include
 - a. watch for sparks or heat sources that could lead to fires.
 - b. warn workers if tasks are causing an excessive risk of fire.
 - c. extinguish any small or incipient-stage fires immediately.
 - d. all of the above.

3. A fire watch should stay in the area during the work and for at least _____ after the work tasks are finished to monitor all areas where hot work was performed to make sure that there are no smoldering materials.
 - a. 5 minutes
 - b. 30 minutes
 - c. 2 hours
 - d. 12 hours

4. Workers designated to fire watch duty must be equipped with fire-extinguishing equipment readily available for
 - a. Class A and Class B fires.
 - b. energized electrical fires.
 - c. the specific types of fires they may encounter.
 - d. grease fires.

5. The fire watch should only attempt to extinguish a fire if
 - a. they are not sufficiently trained.
 - b. fire trucks are already on the way.
 - c. there are at least two fire extinguishers.
 - d. it is within the capacity of their training and the fire-fighting equipment available.

