

SAFETY MEETING QUIZ

Name:

Date:

Safety Topic: V2-81 Fire Protection – Fire Extinguisher Inspections

1. Portable fire extinguishers should be inspected by a trained professional once a year with a visual inspection conducted
 - a. daily.
 - b. weekly.
 - c. monthly.
 - d. randomly.

2. During the visual inspection of the fire extinguisher, verify that the indicator on the pressure gauge is in the _____ operating range.
 - a. blue
 - b. green
 - c. yellow
 - d. red

3. Fire extinguishers should be located in hidden or difficult to reach locations.
 - a. True
 - b. False

4. During the visual inspection of the fire extinguisher, it is important to
 - a. verify that the fire extinguisher hasn't been moved.
 - b. ensure the path to get to the fire extinguisher is clear.
 - c. confirm the tamper-seal is not broken or missing.
 - d. all of the above.

5. Report missing, damaged or used fire extinguishers
 - a. immediately.
 - b. during the next safety meeting.
 - c. within 6 months.
 - d. at the time of the next annual inspection.



SAFETY MEETING QUIZ

ANSWER KEY

Safety Topic: V2-81 Fire Protection – Fire Extinguisher Inspections

1. Portable fire extinguishers should be inspected by a trained professional once a year with a visual inspection conducted
 - a. daily.
 - b. weekly.
 - ☒ c. monthly.
 - d. randomly.

2. During the visual inspection of the fire extinguisher, verify that the indicator on the pressure gauge is in the _____ operating range.
 - a. blue
 - ☒ b. green
 - c. yellow
 - d. red

3. Fire extinguishers should be located in hidden or difficult to reach locations.
 - a. True
 - ☒ b. False

4. During the visual inspection of the fire extinguisher, it is important to
 - a. verify that the fire extinguisher hasn't been moved.
 - b. ensure the path to get to the fire extinguisher is clear.
 - c. confirm the tamper-seal is not broken or missing.
 - ☒ d. all of the above.

5. Report missing, damaged or used fire extinguishers
 - ☒ a. immediately.
 - b. during the next safety meeting.
 - c. within 6 months.
 - d. at the time of the next annual inspection.

