

Model: NCBBK Battery Backup Kit



Features

- Maintains full system operation during transition to facility's backup generator
- Self-contained unit
- Status LED indicator
- Connector and cable provided
- Meets Class 2 energy limited requirements
- Includes charging circuitry

Specifications

Power Requirements: 24V DC @ 0.1A

Weight: 3½ lbs. (1.6 kg)

Size: H: 11½" (29.3 cm)

W: 2" (5.1 cm)

D: 3¾" (9.6 cm)

Housing and Finish: Black metal enclosure w/white nomenclature

Controls: "Charging" LED indicator, On/Off switch

Terminations: Cable w/connector

Power Output: 1.2 Amp-Hour, 14V Nicad Battery @ 6A

Backbox Requirements: Rauland NC2828 terminal cabinet

Certification: UL/C-UL 1069

Description

The NCBBK Battery Backup Kit provides full power for up to five minutes (when fully charged) of full Responder[®] operation in the event of an AC power failure (during the transition to the facility's emergency backup generators). The Battery Backup Kit also provides full power during similar AC brown-out conditions.

The Battery Backup Kit is a completely self-contained unit with an On/Off switch, "Charging" status LED, and a cable with connector to plug into an associated NCPWR Power Supply.

One NCBBK Battery Backup Kit is required for each NCPWR Power Supply in a Responder IV network designed for emergency battery backup.

Associated Equipment

NCPWR — Power Supply

NC2828 — Terminal Cabinet

Architects and Engineers Specifications available on disk. Specifications subject to change without notice.

Rauland-Borg Corporation

3450 West Oakton Street • Skokie, IL 60076-2958 • (847) 679-0900 • (847) 679-0625 Fax • www.rauland.com
In Canada: 4025 Sladeview Crescent, Units 4-6 • Mississauga, ON CANADA L5L 5Y1 • (905) 607-2335 • (905) 607-3554 Fax



Rauland